

March 2009

G200 Series Back Check Valves



WARNING

Failure to follow these instructions or to properly install and maintain this equipment could result in an explosion and/or fire causing property damage and personal injury or death.

Fisher® equipment must be installed, operated, and maintained in accordance with federal, state, and local codes and manufacturer's instructions. The installation in most states must also comply with NFPA No. 58 or ANSI K61.1 standards.

Only personnel trained in the proper procedures, codes, standards, and regulations of the applicable industrial service should install and service this equipment.



P1041

Figure 1. Type G201 Back Check Valve with Flow Indicator Arrow

The soft-seated construction gives tight shutoff. Piping can be blown down easily for maintenance or repair without experiencing leakage.

Introduction

Scope of the Manual

This instruction manual covers installation and maintenance for Fisher® G200 Series Back check Valves used in LP-Gas and anhydrous ammonia bulk plant transfer area vapor and liquid lines.

The Type G201 is identical to the G200 Series but has a built-in flow indicator.

Description

Back check valves allow flow in only one direction and are normally closed. When flow in the direction of the arrow starts, the valve poppet opens. When flow stops or reverses, the valve poppet closes. Back check valves are installed on stationary storage tanks and vapor or liquid transfer lines. The valves are frequently used in conjunction with globe and angle valves.

Specifications



CAUTION

If the valve is to be used in service other than LP-Gas or anhydrous ammonia, contact the factory to determine if the valve materials are suitable for the particular service.

Installation



CAUTION

Flow through the Back check valve must be in the same direction as the flow arrow stamped on the valve nameplate.



G200 Series

Specifications

SEAT CONSTRUCTION	CONTAINER OR INLET CONNECTION	OUTLET CONNECTION	WATER FLOW CAPACITY, GPM (L/MIN) AT 10 PSIG (0,69 bar) DIFFERENTIAL PRESSURE	TYPE NUMBER	
				Ductile Iron	
				Without Flow Indicator	With Flow Indicator
Soft Seat	1-1/4 FNPT	1-1/4 FNPT	160 (606)	G200-10	G201-10
	2 FNPT	2 FNPT	250 (946)	G200-16	G201-16
	3 FNPT	3 FNPT	750 (2839)	G200-24	G201-24

Maximum Operating Pressure
400 psig (27,6 bar) WOG

Temperature Capabilities
-40° to 160°F (-40° to 71°C)

Manually operate the Back check valve's poppet before installation to assure parts were not damaged in shipment or blocked with dirt or foreign material.

Use pipe dope on the male threads of the pipeline. Polytetrafluoroethylene (PTFE) tape or PTFE pipe dope compound is recommended for the male threads of the larger valves such as the NPS 2 and 3 (DN 50 and 80) sizes.

Make certain flow is in the direction of the arrow on the nameplate (flow entering from the flanged end of the valve). Type G200s prevent flow from the other direction.

If installed in horizontal piping, the valve should be positioned with the nameplate at the top. If installed in vertical piping, the flanged end of the unit should be pointed down to assist the spring in closing the poppet.

Because no breakoff fitting can protect unsupported piping from damage, the piping containing the valve must be adequately anchored to protect against physical damage.

Test the valve for proper operation after installation and before placing the system into full service. To make the test, pressure the system through the back check valve and then bleed pressure from the valve inlet piping. Rapid pressure build-up indicates that the valve has malfunctioned.

Prompt repairs should be made by a properly trained serviceman because a malfunctioning valve can create a hazard, such as an explosion, fire, freeze burns, asphyxiation, or the uncontrolled release of product.

Annually test the valve for proper operation.

Before performing any maintenance, bleed off all upstream and downstream pressure.

To replace the seat disk (key 16, Figure 2), remove the end flange (key 2) and pull out the seat ring (key 3). The seat disk (key 16) can then be removed from the seat ring (key 3) and replaced.

To replace the shaft seal X-ring (key 22) in Type G201 units, first remove the screw (key 24) holding the flow indicator (key 23). Hold the shaft (key 20) in place with a 1/8-inch (3,2 mm) diameter pin while unscrewing the plug (key 19). By holding the shaft (key 20), the valve's internal parts are kept from becoming disengaged. Once the plug (key 20) is removed, the X-ring (key 22) can be replaced, or an entire new plug assembly can be installed.

After any repair work, test the valve for leakage and proper operation.

Maintenance and Repair





CAUTION

Do not use a G200 Series valve that leaks, fails to work properly, or that has damaged or missing parts.



WARNING

Trained personnel should test the back check valve in a safe location. To ensure that the valve is still functional, back check closure should be checked annually if there is no other regularly scheduled test program.



T40255_H

□ LUBRICATE

Figure 2. G200 Series Assemblies

G200 Series

Parts List

Key	Description	Part Number	Key	Description	Part Number
1	Body, Ductile iron NPS 1-1/4 NPS 2 NPS 3	T40333X0012 T40245T0012 T80171T0012	12	Tube, 302/304 Stainless steel NPS 1-1/4 NPS 2 NPS 3	T12880T0012 T12544T0012 T12954T0012
2	Flange, Ductile iron NPS 1-1/4 NPS 2 NPS 3	T20681T0012 T12783T0012 T20699T0012	13	Spring (Type G200 only), 302 Stainless steel NPS 1-1/4 and 2 NPS 3	T1188637022 T1153537022 Not Orderable
3*	Seat Ring, Stainless steel 1-1/4-inch (32 mm) 2-inch (51 mm) 3-inch (76 mm)	T12857T0012 T12548T0012 T12887T0012	14	Nameplate	
4	Cap Screw Types G200/G201 - 10 and -16 (4 required) NPS 1-1/4 NPS 2 NPS 3 Types G200/G201 -24 (8 required) NPS 1-1/4 NPS 2 NPS 3	T12864T0012 1E760432992 ----- ----- 1E761499012	15	Drive Screw (2 required), 18-8 Stainless steel	1A368228982
5	Poppet, 303 Stainless steel NPS 1-1/4 NPS 2 NPS 3	T12882T0012 T12550T0012 T12952T0012	16*	Disk, Nitrile (NBR) NPS 1-1/4 NPS 2 NPS 3	T12858T0012 T12547T0012 T12891T0012
6	Nut, Stainless steel/Carbon steel NPS 1-1/4 NPS 2 and 3	T12929T0012 T12930T0012	17*	O-ring, Nitrile (NBR) NPS 1-1/4 NPS 2 NPS 3	10A3800X032 1H8762X0022 T12759T0012
7	Washer, Steel NPS 1-1/4 NPS 2 and 3	T12861T0012 T12780T0012	18*	Gasket, Aluminum NPS 1-1/4, 2, and 3	T12782T0012
8	Pin, 18-8 Stainless steel NPS 1-1/4 NPS 2 and 3	T1241338992 T12933T0012	19	Pipe Plug, 303 Stainless steel Type G200 Type G201	T12554T0012 T12557T0012
9	Bushing NPS 1-1/4, 2, and 3	T12551T0012	20	Shaft, 303 Stainless steel Type G200 NPS 1-1/4 NPS 2 NPS 3	T12881T0012 T12553T0012 T12955T0012
10	Slip Disk, Nylon (PA) Type G200 Type G201	T12781T0012 T12781T0012		Type G201 NPS 1-1/4 NPS 2 NPS 3	T12254T0012 T12749T0012 T12956T0012
11	Spring, 302 Stainless steel NPS 1-1/4 NPS 2 NPS 3	T12883T0012 T12785T0012 T12953T0012	21	Lever, Stainless steel NPS 1-1/4 NPS 2 NPS 3	T12835T0012 T12674T0012 T20701T0012
			22*	X-Ring (Type G201 only) NPS 1-1/4, 2, and 3	T12786T0012
			23	Indicator (Type G201 only), Aluminum NPS 1-1/4, 2, and 3	T12787T0012
			24	Screw (Type G201 only), Carbon steel-plate NPS 1-1/4, 2, and 3	1U205528982
			25	Bushing (Type G201 only) NPS 1-1/4, 2, and 3	T12551T0012
			26	Spacer (Type G201 only), Aluminum	T12827T0012

*Recommended spare part

LP-Gas Equipment

Emerson Process Management Regulator Technologies, Inc.

USA - Headquarters
McKinney, Texas 75070 USA
Tel: 1-800-558-5853
Outside U.S. 1-972-548-3574

For further information visit www.emersonprocess.com/regulators/lp

The Emerson logo is a trademark and service mark of Emerson Electric Co. All other marks are the property of their prospective owners. Fisher is a mark owned by Fisher Controls, Inc., a business of Emerson Process Management.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Process Management does not assume responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use and maintenance of any Emerson Process Management product remains solely with the purchaser.